

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-1209:203 Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: System Sensor, 3825 Ohio Ave, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models EPS10EXP, EPS40EXP, EPS120EXP pressure switches. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: EPS10EXP 4-20 psig
EPS40EXP 10-100 psig
EPS120EXP 10-200 psig

125/250 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as pressure switches for use with dry or wet pipe fire sprinkler systems. Suitable for use in Class I, Group B, C and D; Class II, Group E, F and G hazardous locations.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager